LISTING SERVICE

LISTING No.   7320-1209:138   Page 1 of 1

CATEGORY: Speakers

LISTEE: System Sensor, 3825 Ohio Ave, St. Charles IL 60174
Contact: *Trish Linhart (630) 377-6674 Fax (630) 377-7245

DESIGN: Model V400 speaker with suffix -R or -B. unit is comprised of a cone assembly bracket, magnet, transformer, capacitor, wiring board, and a plastic enclosur with baffle. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 25 or 70 Vrms

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. For indoor use only.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as speakers for use with spearately listed compatible control units. May be used with Models SS-12 or SS-24 strobes (CSFM Listing No. 7300-1209:123).

Ifthis appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

*Rev. 06-16-2003

Date Issued: **JUNE 22, 2004**   *Listing Expires June 30, 2005*

Authorized By: *DIANE K. AREND, Senior Deputy*
Program Manager